



FIRE DOOR SAFETY WEEK

5 THINGS TO CHECK FOR FIRE DOOR SAFETY

1



CERTIFICATION

Look for a label, a plug or similar marking to show that it's certified & follow the instructions.

2



APERTURES

Altering the door for glazing apertures & air transfer grilles will make certification **VOID**.

3



GAPS & SEALS

Check the gap around the door frame is constant & around 3 to 4mm & CE marked hinges are firmly fixed with no missing screws. Ensure seals are fitted at the top & side of the door.

4



CLOSERS

Check that the closer shuts the door onto the latch from any position - check from 75mm from the closed position.

5



OPERATION

Ensure the door closes correctly around all parts of the frame.

IMPORTANT: All ironmongery such as locks, latches, closers & hinges, **MUST** be CE marked & compatible with the door leaf's certification.

CLOSE THE DOOR ON FIRE

For more information visit www.firesafetyweek.co.uk